Christmas Tree Lot Application & Permit

2014 Permit & Inspection Fee - $194.00

Applicant(s) Name _____

Address _____

City _____ State _____ Zip Code_____

Doing Business as _____

Christmas Tree Lot Address _____

Vallejo Business License # _____Local Phone Number _____

Will there be any lot lighting at this site? Yes _____ No _____
Power will be supplied by: Existing Circuit _____ Temporary Power Pole _____ Portable Generator _____

The following are Code requirements for Christmas tree lots within the City of Vallejo (California Fire Code (CFC, Article 32/Appendix IV-B) :

1. Minimum Class 2-A 10:B:C fire extinguisher(s) shall be located in accessible locations, within 75 feet of travel distance to fire extinguishers.
2. Electrical wiring or temporary structures will require an inspection by the City of Vallejo Building Department. Arrangements will need to be made with them directly.
3. Any tree lot doing commercial fire retardant treatment of trees will require a license from the California State Fire Marshal.
4. Fire retardant applications to trees, approved by the California State Fire Marshall, may be sold for treatment to individual customers. Trees must be tagged after treatment.
5. All canopies and temporary shelters must be constructed using fire resistive fabric, as approved by the California State Fire Marshal (T-19, CFC, Article 32).
6. All canopies and temporary shelters must be structurally sound and secured and meet all State and Local Codes.
7. Parking shall be 20 feet from all temporary structures (CFC, Article 32).
8. Customers should be advised that unless flocking material is an approved fire retardant by the California State Fire Marshall, it does not render a tree fire retardant.
9. "No Smoking" signs shall be posted if there is hay, straw, sawdust or any other combustible materials used for floor covering.
10. Heating equipment shall be 10 feet from tents and canopies (CFC, Article 32).

Applicant Signature_____ Date _____

Fire Department Use Only

Application Received _____ Fee Paid _____

Date/Time of Inspection _____ Inspector _____

Fire Clearance Granted _____
(Date & Initials)

This document shall be posted on site for the duration of operation.